

APPENDIX B

STORAGE SYSTEM INSPECTION SUMMARY TABLE

COMPONENT	DAILY	MONTHLY	ANNUAL
Complete daily checklist and compare to previously completed daily checklists		X	
Complete monthly checklist and compare to previously completed monthly checklists			X
Automatic Tank Gauge	X	X	X
Check for Water in Tank		X	
Tank Top and Fuel Dispenser Sumps			X
Fuel dispensers			X
Drop Tube		X	X
Electronic Leak Detector		X	X
Fill Cover	X		
Fill Pipe	X	X	
Electronic Leak Detector (piping)		X	X
Galvanic Corrosion Protection			X
Tank Gauge Stick		X	
Grade Level Covers		X	
Groundwater/Soil Vapor Monitoring		X	X
Impressed Current Corrosion Protection		X	X
Inventory Control	X	X	
Leak Detection Monitor	X	X	X
Manual Interstitial Monitoring		X	
Mechanical Leak Detector (piping)	X		X
Observation Wells		X	X
Overfill Prevention			X
Piping Condition			X
Piping Leak Test		X	
Piping Tightness Test			X
Site Diagram			X
Spill Containment Manhole	X	X	
Stage I Vapor Recovery		X	X
Stage II Vapor Recovery			X
Statistical Inventory Reconciliation		X	
Submersible Turbine Pump			X
Tank Lining			X
Tank Pad and Pavement			X
Tank Tightness Test			X
Tank Vents		X	

TABLE B-1. This table lists alphabetically the components that are included in the daily, monthly, and annual inspections described in this recommended practice and the frequency of inspection for each of these components. Refer to the checklists in Appendix A and Chapters 6, 7, and 8 of this document for detailed descriptions of the inspection procedures.